

HISTORICAL FHI COSTS FOR DER CONNECTIONS

DER Group/kW Size Range	No.	Project Type (Exporting/Non-Exporting)	Connection Cost Estimate (\$)	Actual Connection Cost (\$)	Variance (Actual - Estimate) (\$)	Variance (%)	Expansion Required (Y/N)	Transfer Trip Required (Y/N)	Build and Energization duration (Months)	Notes
Group 1 - All micro-embedded generation facility cost(s) <=12kW	1	Exporting	\$750.00	\$750.00	\$0.00	0%	N	N	2	
	2	Non-Exporting	\$750.00	\$750.00	\$0.00	0%	N	N	2	
Group 2 - 13kW to 249kW	1	Exporting	\$5,876.00	\$4,400.00	-\$1,476.00	-34%	N	N	5	
	2	Exporting	\$15,000.00	\$7,624.00	-\$7,376.00	-97%	N	N	5	
Group 3 - 250kW to 999kW	1	Exporting	\$44,390.00	\$38,452.00	-\$5,938.00	-15%	N	N	20	Duration due to structural concerns that needed to be addressed
	2	Non-Exporting	\$340,309.00	\$328,207.00	-\$12,102.00	-4%	N	y	37	
Group 4 - >1MW	1	Non-Exporting	\$340,309.00	\$328,207.00	-\$12,102.00	-4%	N	y	37	
	2	Non-Exporting	\$403,309.00	\$396,083.00	-\$7,226.00	-2%	N	y	30	